

OFFICE USE ONLY  
 Log No. 37595  
 Permit No. \_\_\_\_\_  
 Basin. 72

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1355

1. OWNER Thomas A. Snyder ADDRESS AT WELL LOCATION No physical address at this location  
 MAILING ADDRESS P.O. Box 215  
Imlay, Nevada 89418

2. LOCATION SW 1/4 SE 1/4 Sec 8 T 32 N/S R 34 E Pershing County  
 PERMIT NO. "NA" 06-090-11 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name Smith

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	10	
Gravel & Sand		10	12	
Clay		12	20	
Gravel & Sand		20	50	
Blue Clay		50	100	
Blue clay		100	110	
Clay w/s Sand		110	112	
Brown clay		112	160	
Clay w/s Sand		160	165	
Clay, Brown		165	180	
Clay & Sand		180	185	
Brown Clay		185	190	

91 DEC-5 NO 146  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 3/4 Inches To 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 5/8</u>		<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:  
 Type perforation Factory  
 Size perforation 3/16  
 From 150 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 Ft.  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 190 feet to 50 feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started Dec. 2 1991  
 Date completed Dec. 3 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name American Drilling Contractor  
 Address P.O. Box 1878 Contractor  
Winnemucca, NV. 89445  
 Nevada contractor's license number issued by the State Contractor's Board 0020578  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 730  
 Signed Shirley La Mours  
 By driller performing actual drilling on site or contractor  
 Date Dec. 3, 1991