


OFFICE USE ONLY
 Log No. 37606
 Permit No. 87
 Basin 87



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 158660

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Sierra Sid's Auto Truck Plaza ADDRESS AT WELL LOCATION Same as Owner
 MAILING ADDRESS 200 North McCarran Blvd.
Sparks, Nevada

2. LOCATION NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 9 T. 19 N S R. 20 E. Washoe County
 PERMIT NO. Waver No. MO-453 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>UMW-1</u>				
<u>Light brown sandy gravel</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Moist sand</u>		<u>10</u>	<u>11</u>	
<u>Light brown sandy gravel</u>		<u>11</u>	<u>14</u>	
<u>Moist sand</u>		<u>14</u>	<u>15</u>	
<u>Light brown sandy gravel</u>		<u>14</u>	<u>20</u>	
<u>Moist sand</u>		<u>20</u>	<u>21</u>	
<u>Dark Brown Sandy gravel</u>		<u>21</u>	<u>36</u>	
<u>Yellowish brown sandy gravel</u>		<u>36</u>	<u>42</u>	
<u>Dark Yellowish Brown sandy gravel</u>		<u>42</u>	<u>70.5</u>	
<u>Free Ground water encountered at app. 55ft.</u>				

8. WELL CONSTRUCTION
 Depth Drilled 70.5 Feet Depth Cascd.....Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches.....Feet.....Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>sch 40 PVC</u>	<u>50</u>	<u>0</u>

Perforations:
 Type perforation Slotted
 Size perforation 0.020"
 From 70 feet to 50 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 44ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 70 feet to 44 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow.....G.P.M.....P.S.I.
 Water temperature.....°F Quality.....

Date started September 14, 1991
 Date completed September 14, 1991

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	<u>7.0</u>		
Draw Down (Feet Below Static)	<u>0.5</u>		
Time (Hours)			

STATE ENGINEERS
 '91 OCT -7 P2
 1991

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Layne Environmental Services, Inc. Contractor
 Address 16018 Valley Blvd. Contractor
Fontana, CA 92335
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1468
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 10/03/91