WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37612
Permit No.
Basin 92A

NOTICE OF INTENT NO. 17987

1. OWNER MEL EVENS
MAILING ADDRESS P.O. BOX 60515
Reno, NV 89506

ADDRESS AT WELL LOCATION 10130 Bodi
Reno, NV 89506

2. LOCATION SE ¼ NE ¼ Sec. 25 T. 21N N/S R. 18 E. Washoe County

PERMIT NO. (Issued by Water Resources) 86-173-09 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	9	9
Brown sandy clay		9	17	8
Soft zone		17	19	2
Brown clay		19	69	50
Soft sandy brown clay		69	83	14
Coarse sands, soft	X	83	93	10
Brown clay		93	98	5
Blue clay		98	105	7

'91 OCT 25 AM 10:41 STATE ENGINEER

Date started 10-17-91, 19
Date completed 10-17-91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10"	Inches	0 Feet	50 Feet
8 5/8"	Inches	50 Feet	105 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	105

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 105 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on site driller 923

Signed (By driller performing actual drilling on site or contractor)
Date October 21, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627