WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37625
Permit No.
Basin 101

NOTICE OF INTENT NO. 17540

1. OWNER Joanne Stellman
MAILING ADDRESS 11625 Sundale Ave.
Hawthorne, Calif. 90250

ADDRESS AT WELL LOCATION 5520 Rivers Edge
Fallon, Nev. 89406

2. LOCATION SE ¼ NW ¼ Sec. 29 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. N/A (Issued by Water Resources) 08-55145 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Coarse Brown Sand		6	22	16
Brown Sand		22	43	21
Black Sand		43	47	4
Black and Green Coarse Sand		47	57	10
Gray Sand		57	66	9
Brown & Green Coarse Sand		66	83	17
Brown Clayish Sand		83	92	9
Gray Sand		92	98	6
Coarse Green & White Sand		98	104	6
Gray Sandy Clay		104	109	5
Green & White Coarse Sand		109	112	3
Gray Sandy Clay		112	117	5
Black & Green Coarse Sand		117	126	9
Gray Sandy Clay		126	129	3
Green & Black Coarse Sand		129	136	7
Brown Clay		136	138	2
Brown Coarse Sand	X	138	150	12

Date started Sept. 23, 19 91
Date completed Sept. 23, 19 91

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	150 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	150

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 144 feet to 148 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nevada 89406

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Doug Parsons
By driller performing actual drilling on site or contractor

Date Oct 10, 1991

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627