WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37637
Permit No. 54903
Basin 212

NOTICE OF INTENT NO. 9400

1. OWNER Wayne F. Upchurch
MAILING ADDRESS 5970 W. Ruffian St.
Las Vegas, Nevada 89129

ADDRESS AT WELL LOCATION
N/A

2. LOCATION NE ¼ SE ¼ Sec. 25 T 19 N/S R 59 E Clark County

PERMIT NO. 54903 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	16	
Cemented Gravel		16	65	
Clay & Gravel		65	195	
Cemented Gravel		195	215	
Clay & Gravel		215	360	
Boulders		360	415	
Clay Gravel		415	510	
Gravel & Water	x	510	530	
Clay & Gravel		530	560	
Gravel & Water	x	560	600	

RECEIVED
MAY 07 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4/16/92, 19
Date completed 4/23/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4"	Inches	0 Feet	55 Feet
9 7/8"	Inches	55 Feet	600 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 7/8"	16.94	.188	+1	600

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 560 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 429 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nevada
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed (By driller performing actual drilling on site or contractor)
Date May 5, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627