

OFFICE USE ONLY
 Log No. 37671
 Permit No. 55774
 Basin 212



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8155

PRINT OR TYPE ONLY

1. OWNER Jimmy Joe Novak ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 726 Santree Circle
Las Vegas, NV 89110

2. LOCATION NW 1/4 NW 1/4 Sec 32 T 19 R 60 E Clark County
 PERMIT NO. 55374 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other Quasi-Municipal

4. PROPOSED USE
 Domestic Irrigation Industrial
 Test Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	6	6
Sand & gravel		6	40	34
Partly cem. sand & grav.		40	100	60
Sand & gravel, clay		100	140	40
Clay		140	180	40
Partly cem. sand & grav.		180	200	20
Cemented sand & gravel		200	300	100
Sand & gravel, clay		300	340	40
Sand & gravel		340	380	40
Sand & gravel, clay		380	400	20
Cemented sand & gravel		400	480	80
Sand & gravel, clay		480	605	125

Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 605 feet
 _____ inches
 _____ inches

Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>8</u> inches	<u>+1</u> feet	<u>605</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 605 feet

Perforations:
 Type perforation Mill slots/ Stainless stl. scrn
 Size perforation 1/8x2 1/2 8 rows / .030 slot
 From Perf. 481 feet to 560 feet
 From Screen 560 feet to 605 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started March 2, 1992
 Date completed March 10, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 350 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. Contractor
4185 W. Harmon
 Address Las Vegas, NV 89103 Contractor

Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada contractor's driller's number issued by the Division of Water Resources 290
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
 Signed Richard R. Thompson
 By driller performing actual drilling on site or contractor
 Date April 7, 1992

