WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37686
Permit No.
Basin

37686

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6169

1. OWNER Al Stevens
MAILING ADDRESS 1298 Bledsoe Lane
Las Vegas, Nevada 89110

ADDRESS AT WELL LOCATION 1298 Bledsoe Lane
Las Vegas, Nevada 89110

2. LOCATION SE ¼ NW ¼ Sec. 28 T. 20 N/S R. 62 E. Clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	22	22
gravel		22	26	4
brown clay		26	44	18
white clay		44	55	11
light brown clay	xx	55	115	60
gravel	xx	115	162	47
gravel	xx	162	165	3
brpwn clay		165	180	15
brown graveley clay	xxxx	180	300	120

RECEIVED
JUN 16 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

RECEIVED
APR 2 6 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-5-92, 19
Date completed 2-17-92, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailed 60	G.P.M. from	56 ft.	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10" inches Total depth 300 feet
inches
inches
Casing record 8 5/8" to 300 ft.
Weight per foot .188 wall Thickness

Diameter	From	To
12" Hole inches	0 feet	50 feet
10" Hole inches	50 feet	300 feet
inches	feet	feet
8 5/8 inches casing	0 feet	300 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/16" X 10"
From 55 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 47 ft feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S. R. McKinney & Sons, Inc. (Contractor)
Address 1042 South Main St. Las Vegas, Nevada 8910 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 2065
Nevada contractor's driller's number issued by the Division of Water Resources 45
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 270
Signed (By driller performing actual drilling on site or contractor)
Date 3-2-92

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627