WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 37688
Permit No. 54527
Basin

NOTICE OF INTENT NO. 8165

1. OWNER Karl Probst
MAILING ADDRESS Probst Family Construction
1701 Katie, Ste. 64, Las Vegas, NV 891119
ADDRESS AT WELL LOCATION
2. LOCATION SW ¼ NE ¼ Sec. 35 T. 20 S R. 62 E. Clark County
PERMIT NO. 54527 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐ Quasi-

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	15	15
Conglomerate		15	265	250
Limestone		265	300	35
Red rock		300	310	10
Gravel & sand		310	320	10
Boulders & limestone		320	335	15
Boulders & limestone		335	435	100

RECEIVED
MAR 18 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started February 25, 1992
Date completed March 4, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 435 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness 3/16

Diameter	From	To
8 inches	+1 feet	435 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 53 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 53 feet to 435 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8"
From 335 feet to 415 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 280 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon, Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1750
Signed Richard R. Thompson (By driller performing actual drilling on site or contractor)
Date March 16, 1992

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627