WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37028
Permit No. 54908
Basin

NOTICE OF INTENT NO. 11177

1. OWNER HAROLD LONG
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SE ¼ Sec. 17 T. 22 X/S R. 60 E. CLARK County
PERMIT NO. 54908 #1 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND-CLAY-ROCKS		0	3	3
CMT GRAVEL W/		3		
STREAK OF CLAY			250	247
CMT GRAVEL W/ STREAK				
OF RED SAND STONE		250	395	145
LIME STONE		395	415	20
CMT GRAVEL W/ STREAK				
RED SAND STONE		415	690	275
CMT GRAVEL W/		690	850	160
BAD FRACTURES				

RECEIVED
APR 06 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-10-92, 19
Date completed 4-1-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 850 Feet Depth Cased 850 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	850 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	850

Perforations:
Type perforation FACTORY
Size perforation 3" x 1/4"
From 810 feet to 850 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 850 feet

9. WATER LEVEL
Static water level 645 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LEE R. THOMAS (Contractor)
Address 5965 N. MAVERICK (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10831
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed Lee R. Thomas (By driller performing actual drilling on site or contractor)
Date 4-1-92

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627