WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37731
Permit No. 54492
Basin

NOTICE OF INTENT NO. 3314

1. OWNER Ernie Becker Jr.
MAILING ADDRESS 50 So. Jones Blvd.
Las Vegas, Nev. 89107

ADDRESS AT WELL LOCATION Rainbow & Blueddamond

2. LOCATION SE NE ¼ NE ¼ Sec. 22 T. 22 N/S R. 60 E. Clark County
PERMIT NO. 54492 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & gravel		0	6	6
cemented conglomerate		6	7	1
silt sand & gravel		7	72	65
cemented conglomerate		72	76	4
sand & gravel		76	96	20
cemented conglomerate		96	114	18
sand & gravel		114	313	199
brown clay sand & gravel		313	390	77
red clay sand & gravel		390	410	20
yellow clay sand & gravel		410	454	44
cemented conglomerate		454	466	12
gray clay sand & gravel		466	475	9
gravel conglomerate		475	518	43
fractured limestone		518	523	5
limestone		523	540	17
fractured		540	546	6
limestone		546	562	16
red sand stone		562	600	38

RECEIVED
MAY 12 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-21, 19 92
Date completed 4-24, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	?	2

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	600 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1	600

Perforations:
Type perforation Torch
Size perforation 3/16 x 6 x 4 around
From 450 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 460 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc (Contractor)
Address 4847 So. Valley View (Contractor)
Las Vegas, Nev. 89103

Nevada contractor's license number issued by the State Contractor's Board 0018917

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald L. Wall (By driller performing actual drilling on site or contractor)

Date May 8, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627