WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37733
Permit No. 54585
Basin

NOTICE OF INTENT NO. 3227

1. OWNER Jack Disandro
MAILING ADDRESS 4830 Robindale
Las Vegas, NV 89118

ADDRESS AT WELL LOCATION N/A

2. LOCATION NE ¼ NW ¼ Sec. 22 T 22s N/S R 60 E Clark County
PERMIT NO. 54585 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	12	
Cemented gravel		12	15	
Gravel		15	145	
Cemented Gravel		145	160	
Clay & gravel		160	370	
Boulders		370	415	
Clay & gravel		415	585	
Gravel & Water		585	650	

RECEIVED
JUN 24 1992
Division of Water Resources
Branch Office - Las Vegas, NV

Date started May 4, 19 92
Date completed May 8, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	55 Feet
9 7/8 Inches	55 Feet	650 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	650

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 raw
From 610 feet to 630 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 490 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Dimick Contractor
Address 3035 S. Torrey Pines Contractor
Las Vegas, NV 891002
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. Dimick By driller performing actual drilling on site or contractor
Date June 22, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627