WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37756
Permit No.
Basin 104

NOTICE OF INTENT NO. 14803

1. OWNER N.D.O.T. Right of Way
MAILING ADDRESS 1263 S. Stewart St.
Carson City, NV 89712

ADDRESS AT WELL LOCATION W. side of 1090 Joanne Dr.
West side of Joanne Drive, 1000' South of
Fairview Drive, Carson City, NV 89701

2. LOCATION NE ¼ SW ¼ Sec. 21 T. 15N N/S R. 20 E. Carson County

PERMIT NO. Issued by Water Resources | 10-061-07 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon well with neat cement after perforating				
at 5' intervals from 84' to top.				
We used approximately 2.5 yards neat cement				
to abandon the well.				

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.250	-2	-84'

Perforations:
Type perforation Mills Knife
Size perforation
From -84 feet to top feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal filled to top
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719

Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor

Date 9-06-'91

Date started 8-26, 19 91
Date completed 9-06, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10:00	62 100	16.	

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627