WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37761
Permit No.
Basin 105

NOTICE OF INTENT NO. 19470

1. OWNER Ken Rogers
MAILING ADDRESS 2919 Devenpeck
ADDRESS AT WELL LOCATION 2919 Devenpeck

2. LOCATION SW ¼ NW ¼ Sec. 35 T. 11 N/S R. 21 E/W Douglas County
PERMIT NO. (Issued by Water Resources) 35-310 (Parcel No.) 33 Meier Parcel Map (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	25	25
Clay w/Cemented Gravel		25	30	5
Gravels		30	35	5
Cemented Gravel		35	80	45
Gravels w/ Volcanic		80	110	20
Broken hard Volcanic		110	180	70
Broken hard Volcanic w/Small amount of water	XXX	180	230	50
hard black Volcanic		230	260	30
Red Volcanic		260	340	80
Broken Red + Black Volcanic w/ large amount of water 360 T.D.	XXX	340	360	40

Date started 10-4, 19
Date completed 10-17, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45	240'	2

8. WELL CONSTRUCTION
Depth Drilled 360' Feet Depth Cased 360' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 3/4 Inches	0 Feet	55' Feet
9 7/8 Inches	55' Feet	360 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	230
5 9/16	11.04	.188	220	360

Perforations:
Type perforation Mill Slot
Size perforation 3½ X 3/32
From 210' feet to 360' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 360' feet

9. WATER LEVEL
Static water level 260' feet below land surface
Artesian flow G.P.M. 35-40 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co. (Contractor)
Address 5551 Hyson E. #33 C.C.N.V. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 10-17-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627