WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37765
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 19483

1. OWNER Virginia Brents
MAILING ADDRESS 626 Clylesdale
Gradenville NV 89410

ADDRESS AT WELL LOCATION 626 Clylesdale
Gardner Ville NV 89410

2. LOCATION NE ¼ SW ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 29-520-28 Parcel No. | Ruehen Stroth Flats Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Over Burden Clay		0'	14'	14
Cobble Stones		14'	60'	54
Gravel	X	60'	109	49
Clay & SAND		109	115	6'
Bolders		115	125	10
Level Gravels	X	125	160'	35

'91 DEC -2 P1:57
RECEIVED
STATE ENGINEERS OFFICE

Date started Oct 31, 1991
Date completed NOV 1, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	10FT	2½

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5/8	14	188	+2'	160'

Perforations:
Type perforation Mill Slot
Size perforation 3X3/32
From 120' feet to 160' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50' feet to 160' feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow NO G.P.M. 20+ P.S.I.
Water temperature Cool °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDLCO Drilling Co (Contractor)
Address 1443 Hwy 395 S. (Contractor)
GARDNer Ville NV 89410
Nevada contractor's license number issued by the State Contractor's Board 24149
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1544
Signed Marvin L. Hoer (By driller performing actual drilling on site or contractor)
Date NOV 4 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627