

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17451

1. OWNER Clyde Nelson ADDRESS AT WELL LOCATION 1840 Long Ct  
 MAILING ADDRESS 1840 Long Ct, Gardnerville Gardnerville, Nev. 89410  
 2. LOCATION NW 1/4 SW 1/4 Sec. 24 T. 12N N/S R. 20E E Douglas County  
 PERMIT NO. 29-502-13 Ruhenstroth Ranchos Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles & Clay		0	46	46
Clay		46	53	7
Gravel, loose		53	57	4
Gravel, Consolidated	X	57	142	85
Gravel	X	142	204	62
Clay, Brown		204	210	6

'91 OCT 16 AM 10:02  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 210 Feet Depth Cased 210 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/2 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 170 Feet  
6 1/8 Inches 170 Feet 210 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		0.188	0	170
5 9/16		0.188	162	210

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3/32 X 3"  
 From 100 feet to 120 feet  
 From 140 feet to 182 feet  
 From 190 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 170 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Not Known

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Pre-Cambrian Drilling Co. Inc. Contractor  
 Address 794 Foothill Rd. Gardnerville Contractor  
Nev. 89410  
 Nevada contractor's license number issued by the State Contractor's Board 0030267  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 10/10/91

Date started 9/19, 1991  
 Date completed 9/27, 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		3