

OFFICE USE ONLY
Log No. 37773
Permit No. _____
Basin 8-105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18249

1. OWNER Heavenly Valley Ski Area ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P. O. Box 2180 Ski - area
Stateline, Nv 89449 Air compressor station

2. LOCATION SE 1/4 SW 1/4 Sec 31 T. 13 N/S R. 19 E. Douglas County _____
PERMIT NO. 50039-56729-T Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	7	7
D. G.		7	19	12
Granite - salt & pepper		19	350	331
Heavy fractures				
170 to 193				
240 to 290				
This sanitary seal took 6345 #'s cement				
T.D. 350 ft				
There is a 20 ft blank on bottom of perforation string				

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
12	0	100		
10	100	350		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	+ 2	350

Perforations: Type perforation factory
Size perforation 3/32 X 3 triple
From 230 feet to 330 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 100 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From 100 feet to 350 feet

9. WATER LEVEL
Static water level 89 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

Date started 9/16/91, 19_____
Date completed 10/8/91, 19_____
TEST METHOD: Bailer Pump Air Lift

7. WELL TEST DATA

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
37	213	24

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc
Contractor
Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
Contractor
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada driller's license number issued by the 1132
Division of Water Resources, the on-site driller
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date Roger M. Thrall 10/11/91