WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 3775
Permit No.
Basin 105

NOTICE OF INTENT NO. 19477

1. OWNER Craig U Land (Builder) ADDRESS AT WELL LOCATION 2030 East Valley Rd. Gardnerville NV.
MAILING ADDRESS 2030 East Valley Rd. Gardnerville NV

2. LOCATION SE ¼ SW ¼ Sec. 14 T. 13 N/S R. 20 E Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 23-270-42 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	2	2
hard sand		2	10	8
Gravel w/Small Clay Seams		10	105	95
Clay		105	115	10
Gravels	xxx	115	165	50
Clay		165	185	20
Gravels	xxx	185	200	15
T.D 200'				

Date started 10/21/91
Date completed 10/25/91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-40	30'	3 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	100 Feet
10 Inches		100' Feet	200' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
Type perforation Mill Slot
Size perforation 3½ x 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 100' feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. 30-40 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name F+H. Pump Co. Contractor
Address 5551 Hy. 50 East #3 Contractor
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts By driller performing actual drilling on site or contractor
Date 10-4-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627