WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37776
Permit No.
Basin 105

NOTICE OF INTENT NO. 19277

1. OWNER: Mike Schiller
MAILING ADDRESS: Po Box 1206 GARDNERVILLE, NV 89410
ADDRESS AT WELL LOCATION: 1590 EAST VALLEY GARDNERVILLE, NV 89410

2. LOCATION: SE ¼ SW ¼ Sec. 26 T 13 N/S R 20 E Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 23-290-65 | Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Top soil		0	3	3
Cobbles, sandy clay		3	12	9
clay		12	17	5
cobbles, small gravel		17	20	3
Sand, small gravel, clay STREAKS		20	45	25
clay		45	49	4
Sand, gravel		49	55	6
clay		55	65	10
Sand, gravel		65	95	30
clay		95	105	10
Sand, larger gravel	X	105	118	13
clay		118	125	7
Sand, gravel	X	125	135	10
clay		135	140	5
Sand, gravel	X	140	169	29
clay		169	172	3

Date started 9-6, 1991
Date completed 9-7, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	172 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	172

Perforations:
Type perforation: FACTORY SLOT
Size perforation: 3/32" X 3"
From 132 feet to 172 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 172 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow ~~0~~ G.P.M. 10 ~~PSI~~
Water temperature Cold °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Energy Exploration Drilling
Address (Contractor): Po Box 1538 Minden, NV 89423
Nevada contractor's license number issued by the State Contractor's Board: 21491
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1407
Signed: Jim Wirth (By driller performing actual drilling on site or contractor)
Date: 9-10-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627