

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19469

1. OWNER DR REX BARNETT (ISAMEN) ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 710 W Washington 3548 Mount Blanc
Carson City, NV 89703 Carson City, NV 89705
 2. LOCATION SE 1/4 NW 1/4 Sec 11 T 14 N/S R 19 E Douglas County
 PERMIT NO. 15-080-21 Alpine View Estates #2
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden and blow sand		0	15	15
DG sand, medium soft		15	60	45
DG sand, hard		60	95	35
DG w/fractures, little water, (2 gpm)	xx	95	115	20
DG Sand, hard		115	130	15
DG sand & gravels		130	145	15
Highly fractured DG	xx	145	160	15
TD: 160 feet				
Well capacity: 25 gpm				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 3/4 Inches 0 Feet 60 Feet
9 1/2 Inches 60 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>72</u>	<u>160</u>

Perforations:
 Type perforation 3" x 3/32" Factory slotted
 Size perforation 3" x 3/32"
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
 Contractor
 Address 5551 Hiway 50 E #3, Carson City NV 89701
 Contractor

Date started Sept 3, 1991
 Date completed Sept 6, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Gravel packed and developed well with air. Blowing 25 gpm from 130 feet.			

Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1574
 Signed Joye Batts
 By driller performing actual drilling on site or contractor
 Date 9/7/91