WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37781
Permit No.
Basin 105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17638

1. OWNER D. SCHULZ
MAILING ADDRESS BOX 11827
RENO, NEVADA 89501

ADDRESS AT WELL LOCATION 6701 CENTER
CARSON CITY, NV

2. LOCATION SW ¼ NE ¼ Sec. 5 T. 14 N/S R. 20 E. CARSON CITY County
PERMIT NO. (Issued by Water Resources) [redacted] #2 (Parcel No.) NONE / JR SCHULL ESTATE (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	2	2
SILTY CEMENTED LOAM		2	9	7
SOFT OXIDIZED RO-	BUN	9	18	9
ALL DG				
SMALL GRVL IN ALL		18	21	3
DG				
SOFT AL DG W THIN		21	48	27
BEDS OF SMALL GRVL				
& SOFT TAN CLAY				
AL DG W MORE CLAY		48	66	18
AL DG W MINOR		66	195	129
GRY GRNT FRAGS @165'				
AL DG LARGER		195	337	142
FRAGS @ 309'				
SS, GRANITE COMP		337	354	17
AL DG		354	474	120
TAN CLAY, THIN		474	507	33
V HARD CLAY				
HARD, BLDRS, COBBLES		507	513	6
GRANITE				
BLACK GRANITE		513	517	4

Date started 12/6, 1991
Date completed 12/11, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
NA			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. NA Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 517 feet
____ inches
____ inches
Casing record
Weight per foot ____ Thickness .188

Diameter	From	To
6⅝ inches	+2 feet	517 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE GROUT
Depth of seal 124 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 124 feet to 517 feet

Perforations:
Type perforation SAWCUT
Size perforation 2" X 3/32
From 124 feet to 504 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 11 feet below land surface
Flow 300+ G.P.M. AIR LIFT P.S.I.
Water temperature 51°F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRLG, INC (Contractor)
Address BOX 21548 CC, NV 89721 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada contractor's driller's number issued by the Division of Water Resources 1539
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1539
Signed Joseph F. Reisch
(By driller performing actual drilling on site or contractor)
Date 12/05/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627