

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16602

1. OWNER A. J. LOCKLEAR ADDRESS AT WELL LOCATION 339 ARTZ ST. U. FLOW RD. W. R. H. INGRAN, NV. 89444
MAILING ADDRESS 1713 U. FLOW RD. U. FLOW RD. W. R. H. INGRAN, NV. 89444
2. LOCATION NE 1/4 NW 1/4 Sec. 23 T. 11 S. R. 23 E. LYON County
PERMIT NO. 09-101-15 Lot # 3 ARTZ ST. U. FLOW RD. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Hard Pan		3	4	1
Fine to Coarse Sand		4	26	22
Clay & Gravel		26	34	8
Coarse Sand		34	45	11
Coarse Sand & Gravel		45	56	11
Coarse Sand & Gravel, Few Rock		56	78	22
Fine to Coarse Sand		78	90	12
Coarse Sand & Gravel, Few Rock	X	90	118'9"	28'9"

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 119'9" feet
Casing record
Weight per foot 16.94 Thickness .188
Diameter 8 7/8 inches From +1 feet To 118'9" feet
Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 118'9" feet
Perforations:
Type perforation Factory Sawn
Size perforation 3/32 x 3" 8 Rows
From 98'9" feet to 118'9" feet
From _____ feet to _____ feet

Date started 11-2 1991
Date completed 11-18 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>100 Plus</u>	<u>32'6"</u>	<u>60</u>

BAILER TEST
G.P.M. 20 Draw down 5 feet 1/2 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
Static water level 35'6" feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature 60.4 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Osden Bros Drilling Contractor
Address 162 N. BYBEE Lane Yerington Contractor
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed James Osden By driller performing actual drilling on site or contractor
Date 11-24-91