WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37798
Permit No.
Basin 108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16613

1. OWNER Albert J. Burckhard
MAILING ADDRESS 4608 Neil Rd. #222 Reno, NV 89502
ADDRESS AT WELL LOCATION #27 Thurston Way Yerington, NV 89447

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 13 (N) S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 14-592-08 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine to Coarse Sand		0	5	5
Coarse sand, gravel, few rock fill		5	32	27
Coarse sand, gravel, few rock fill w/ clay		32	40	8
Coarse sand, gravel, rock fill		40	45	5
Coarse sand, gravel, Clay		45	48	3
Coarse sand, gravel few rock w/ clay stratas		48	110	62
fractured rock, green clay		110	115	5
Green fractured rock		115	122	7
Coarse sand, gravel, rock		122	141	19
fractured rock w/ clay Stratas		141	155	14

Date started 9-18, 1991
Date completed 9-23, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 4 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 155 feet
inches
inches
Casing record
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	+1 feet	154 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 154 feet

Perforations:
Type perforation Sawed
Size perforation 3/32" X 3" X 6 rows
From 134 feet to 154 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 76 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Coden Bros Drilling Contractor
Address 162 N. Bybee Ln. Yerington, NV 89447 Contractor
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-23-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627