WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37799
Permit No.
Basin 108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16612

1. OWNER Vince Dye
MAILING ADDRESS 120 Penrose Lane
Yerington NV 89447

ADDRESS AT WELL LOCATION See legal description

2. LOCATION N.W. ¼ NE ¼ Sec. 10 T. 14 N/S R. 25 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 14-221-19 | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil (clay)		0	3	3
Clay, sand		3	15	12
Coarse sand		15	22	7
blue-gray clay, sand, gravel		22	31	9
blue-gray clay, sand		31	44	13
blue-gray clay, brown clay		44	48	4
brown clay, coarse sand		48	55	7
coarse sand, gravel		55	61	6
blue-gray clay, coarse sand		61	70	9
blue-gray clay, brown clay, coarse sand, gravel	X	70	75	5
blue-gray clay, coarse sand		75	82	7
brown clay, sand		82	106	24
brown clay, coarse sand		106	121	15
coarse sand, gravel	X	121	140'4"	19'4"

Date started 9-3, 1991
Date completed 9-6, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 12 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 140'4" feet
inches
inches
Casing record
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	+1 feet	139'4" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 139'4" feet

Perforations:
Type perforation Sawed
Size perforation 3/32" X 3" X 66 gauge
From 119'4" feet to 139'4" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 28 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros. Drilling (Contractor)
Address 162 N. Bybee Ln. Yerington, NV 89447 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [illegible] (By driller performing actual drilling on site or contractor)
Date 9-23-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627