

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16616  
135 N HWY 95A

1. OWNER ANNE EVANS ADDRESS AT WELL LOCATION Yerington Nev 89447  
 MAILING ADDRESS 135 N HWY 95A  
Yerington Nev 89447  
 2. LOCATION SE 1/4 SE 1/4 Sec 16 T 14 N 25 E Lyon County  
 PERMIT NO. 14-231-13 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy Clay		0	2	2
Sandy Clay		2	8	6
Coarse Sand		8	20	12
Coarse Sand & Gravel		20	32	12
Bluish Clay & Gravel		32	34	2
Coarse Sand		34	36	2
Black & Greenish Clay & Gravel		36	38	2
Coarse Sand & Brown Clay		38	40	2
Coarse Sand & Gravel		40	52	12
Brown Clay, Coarse Sand & Gravel		52	57	5
Coarse Sand & Gravel		57	70	13
Clay, Coarse Sand & Gravel		70	84	14
Coarse Sand & Gravel		84	126	42
Brown Clay		126	130	4
Coarse Sand & Brown Clay Strata	X	130	149	19

8. WELL CONSTRUCTION  
 Diameter 10 5/8" inches Total depth 150' feet  
 Casing record \_\_\_\_\_ inches  
 Weight per foot 12.92 Thickness 1.08  
 Diameter \_\_\_\_\_ inches From \_\_\_\_\_ feet To \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 100' feet  
 Gravel packed: Yes  No   
 Gravel packed from 100 feet to 149 feet  
 Perforations:  
 Type perforation Sawed  
 Size perforation 3/32 x 3" x 6 Rows  
 From 129 feet to 149 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-11, 1991  
 Date completed 12-14, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>37</u>	<u>12'6"</u>	<u>1/2</u>

BAILER TEST  
 G.P.M. 30 Draw down 30 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 20'6" feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Opden Bros Drilling Contractor  
 Address 162 N ByBee Lane Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada contractor's driller's number issued by the Division of Water Resources 634  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Larry Opden  
 By driller performing actual drilling on site or contractor  
 Date 12-18-91

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16617

1. OWNER ANNE EVANS ADDRESS AT WELL LOCATION 135 N Hwy 95-A  
Yerington Nev 89447  
 MAILING ADDRESS 135 N Hwy 95-A  
Yerington Nev 89447  
 2. LOCATION SE 1/4 SE 1/4 Sec. 16 T. 14 N. R. 25 E. Lyon County  
 PERMIT NO. 14-231-13 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ABANDON</u>				
<u>KNIFE 4 HOLES EVERY 5' START AT 60' TO 28'</u>				
<u>28' TO 5'</u>				
<u>LOSS SURFACE SEAL</u>				
<u>Place Next Cement From 61' TO 2'</u>				

8. WELL CONSTRUCTION  
 Diameter 6" ID inches Total depth 61 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 1.56  

Diameter	From	To
<u>6" ID</u> inches	<u>2</u> feet	<u>61</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-16, 1991  
 Date completed 12-17, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 25' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Fair

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros DRILLING Contractor  
 Address 162 N. Bybee Lane Yerington Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada contractor's driller's number issued by the Division of Water Resources 634  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Larry Ogden  
 By driller performing actual drilling on site or contractor  
 Date 12-18-91

BAILER TEST

G.P.M.	Draw down	feet	hours