WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37804
Permit No.
Basin 110 110A

NOTICE OF INTENT NO. 18724

1. OWNER Walker Piute Reservation
MAILING ADDRESS P.O.BOX 220
Schurz, Nevada 89427

ADDRESS AT WELL LOCATION 1/4 mi. South of Schurz Smoke Shop 500 ft. East of Highway 95 Schurz, Nevada

2. LOCATION NE ¼ NW ¼ Sec. 1 T. 12 N/S R. 28 E. Mineral County

PERMIT NO. - (Issued by Water Resources) | Parcel No. - | Subdivision Name -

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Back Fill		0	6	6
Clay & Gravel (lrg.)		6	15	9
Sandy/ Brown Clay/ With Some Rock		15	60	45
Brn.Clay/ DG Stringers		60	170	110
Brn.Clay/ DG Stringers		170	180	10
Brn.Clay/ Some Sand Stringers		180	235	55
Brown Clay		235	240	5

91 DEC 20 A11:19 RECEIVED STATE ENGINEERS OFFICE

Date started Dec. 9, 1991
Date completed Dec. 15, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	air on rig	3 1/2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
14 3/4	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	28.04	.250	+2	90

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3
From 90 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co. (Contractor)
Address P.O.BOX 590 (Contractor)
Winnemucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
Signed C C Engler (By driller performing actual drilling on site or contractor)
Date 12-18-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627