WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37813
Permit No.
Basin 4-48

NOTICE OF INTENT NO. 18915

1. OWNER THOMAS ACHURRA
MAILING ADDRESS Waysack
Elko, NV 89801
ADDRESS AT WELL LOCATION 11 miles south of Elko off Lamoille Highway

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 33 N/S R. 57 E. Elko County
PERMIT NO. Ser# 56726T (Issued by Water Resources) 06-52C-02-1 (Parcel No.) ✓ (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Siltstone-brown		0	15	15
Siltstone-soft		15	20	5
Sandy clay-brown		20	45	25
Sandy clay-blue gray		45	55	10
Sand-clean white	x	55	80	25
Clay-light brown		80	100	20
Sandy clay-lt brown		100	130	30
Clay-blue		130	155	25
Sandy clay-blue brown		155	175	20
Sandy clay-mostly blue		175	235	60
Clay-brown		235	275	40
Sand-brownfine	x	275	355	80
Sand-brown coarse	x	355	465	110
Siltstone-brown		465	475	10

Date started November 6, 1991
Date completed November 7, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 475 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5-5/8 Inches	0 Feet	475 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1120
Signed (By driller performing actual drilling on site or contractor)
Date 11-11-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627