TB-103

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37834
Permit No.
Basin 61

NOTICE OF INTENT NO. 14941

1. OWNER DEE GOLD MINING COMPANY
MAILING ADDRESS P. O. Box 1193
Elko, NV 89801

ADDRESS AT WELL LOCATION
24 miles NE of Dunphy
Exit off I-80

2. LOCATION SW ¼ SW ¼ Sec 10 T 36 N/S R 49 E Elko County

PERMIT NO. M-0-357-A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cut off 6" PVC | | | | |
| at Surface & | | | | |
| Mixed 6 gal of | | | | |
| Water Per Sx | | | | |
| of Portland Cement | | | | |
| & Poured | | | | |
| Filled Casing | | | | |
| from 70' to 0' | | | | |
| Used 18 sx's | | | | |
| of Portland | | | | |
| 18-Sxs Portland | Cement | | | |

Date started 12-18-91, 19
Date completed 12-18-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled [redacted] Feet Depth Cased 70' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6" PVC | | Sch-40 | 0 | 70' |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 38' Appx feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EKLUND DRILLING COMPANY, INC. (Contractor)
Address P. O. Box 2786 (Contractor)
Elko, NV 89801

Nevada contractor's license number issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1762

Signed Floyd H. Waddell (Pete)
By driller performing actual drilling on site or contractor

Date 12-20-91

JAN 7 92 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627