

TB-6

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 37842  
Permit No. \_\_\_\_\_  
Basin 61

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14941

1. OWNER DEE GOLD MINING COMPANY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P. O. Box 1193 24 miles NE of Dunphy  
Elko, NV 89801 Exit off I-80

2. LOCATION SE 1/4 SW 1/4 Sec. 10 T. 36 N/S R. 49 E. Elko County \_\_\_\_\_  
 PERMIT NO. M-0-357-A Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Drilled out Hole TB-6 with Air + 6" Tricone</u>				
<u>from 0' to 35'</u>				
<u>Drilled out 2" PVC + Bentonite</u>				
<u>Hole Stood Open</u>				
<u>Mixed Cement at base of water</u>				
<u>run 5x3 + Portland + poured</u>				
<u>Filled Hole from 35' to 0'</u>				
<u>used 9-5x3 of Portland</u>				
<u>9-5x3 Portland Cement</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 34.5 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
6" Inches 0 Feet 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2" PVC</u>		<u>SCA-40</u>	<u>0</u>	<u>35</u>

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal 35'  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 20' Appx feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EKLUND DRILLING COMPANY, INC. Contractor  
 Address P. O. Box 2786 Contractor  
Elko, NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1762  
 Signed Floyd D. Woodruff (Petu)  
 By driller performing actual drilling on site or contractor  
 Date 12-20-91

Date started 12-18-91, 19\_\_\_\_  
 Date completed 12-18-91, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)