

OFFICE USE ONLY
 Log No. 37878
 Permit No. _____
 Basin 87. Truckee Meadows

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17308

1. OWNER Jon Mayer ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 485 S. Rock Blvd 5950 Mt Rose Hwy
Reno, Nv 89502

2. LOCATION SW 1/4 SW 1/4 Sec. 26 T. 18 N/S R. 19 E. Washoe County
 PERMIT NO. 049-040-51 Parcel No. _____ Parcel 2 of Map 2420 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Cobbles rocks boulders from top to bottom | | 0 | 368 | 368 |
| T.D. 368 feet | | | | |
| There is a 4 foot blank on the bottom of the perforated casing to aid in development. | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 368 Feet Depth Cased 362 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From | To | Feet | Feet |
|---------------|-----------|------------|------|------|
| <u>10 5/8</u> | <u>0</u> | <u>56</u> | | |
| <u>8 1/2</u> | <u>56</u> | <u>368</u> | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|---------------|------------|
| <u>6 5/8</u> | <u>12.92</u> | <u>.188</u> | <u>+1 1/2</u> | <u>362</u> |

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 338 feet to 358 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 55 feet to 362 feet

9. WATER LEVEL
 Static water level 285 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431 Contractor
 Nevada contractor's license number 15291 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 5/23/91

Date started 5/20/91, 19____
 Date completed 5/22/91, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>20+</u> | <u>clean and develop.</u> | <u>3</u> |

'91 DEC 27 AM 10:46
 STATE ENGINEERS OFFICE