

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20133

1. OWNER Client Geraghty & Miller, Inc. ADDRESS AT WELL LOCATION Chevron Sparks Terminal
 MAILING ADDRESS 5270 Neil Road, Suite 101, 275 Nugget Avenue,
Reno, NV 89502 Sparks, NV 89431

2. LOCATION NW 1/4 NW 1/4 Sec 9 T 19 N N/S R 20 E Washoe County
 PERMIT NO. M/O - 452 / CMW-3 Sparks Terminal NV07002
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	1	1
Dark gray sandy gravel (GM) dry, loose gravel is well rounded and common. Minor small roots are visible.		1	5	4
Olive gray silty sand (SM) dry, loose contains minor rounded gravel to 1 inch.		5	9	4
Olive gray sandy gravel (GW) moist, loose gravels are rounded and range up to 2 inches in diameter. Color grading to dark yellowish brown. Soil wet below 24 feet.	X	9	34,3	25,3

8. WELL CONSTRUCTION
 Depth Drilled 34,3 Feet Depth Cased 33,8 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 34,3 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40 PVC	0	33,8
4"		Locking watertight cap		
4"		Box cap		

Perforations:
 Type perforation Factory sawed slot
 Size perforation 0,020 x 1 1/2 x 6
 From 19 feet to 33,8 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 2 1/2 ft. Bentonite 7 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured 2 ft. Concrete Grout

Gravel Packed: Yes No
 From 17 feet to 34,3 feet

9. WATER LEVEL
 Static water level 23,94 / 10-16-91 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature N/A °F Quality Not known

Date started 10-8-91, 19____
 Date completed 10-8-91, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 3-23-92