

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2370

1. OWNER MARK J Henderson ADDRESS AT WELL LOCATION 133 Adelphi Lane Reno Nev
 MAILING ADDRESS 10250 Timpe Court Reno Nev

2. LOCATION 7E 1/4 S 20 1/4 Sec 4 T 17 N N/S R 20 E Washoe County
 PERMIT NO. 17-330-39 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	22	
Clay + sand		22	33	
SAND		33	40	
CLAY + sand		40	102	
CLAY + sand		102	184	

RECEIVED
 STATE ENGINEERS OFFICE
 '91 OCT -4 AM 1:25

RECEIVED
 STATE ENGINEERS OFFICE
 '91 NOV 18 AM 1:53

8. WELL CONSTRUCTION
 Depth Drilled 184 Feet Depth Cased 184 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 184
1 1/4 Inches 0 Feet 184 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>16.54</u>	<u>12802 1/4</u>	<u>0</u>	<u>184</u>

Perforations:
 Type perforation FACTORY
 Size perforation 1 1/2" 2" 5/8"
 From 100 feet to 184 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100 ft

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 100 feet to 184 feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow 30 G.P.M. P.S.I.
 Water temperature 60.0 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name McKay Drilling Contractor
 Address 2280 Pioneer Dr Reno Nev 89509 Contractor
 Nevada contractor's license number 01417 issued by the State Contractor's Board
 Nevada driller's license number issued by the 786 Division of Water Resources, the on-site driller
 Signed Frank McKay
 By driller performing actual drilling on site or contractor
 Date Sept 30, 1991

Date started Sept 11, 1991
 Date completed Sept 14, 1991

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>7 ft</u>	<u>2 hrs</u>