WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37906
Permit No.
Basin 101

NOTICE OF INTENT NO. 19527

1. OWNER Mr. Winterling
MAILING ADDRESS 2715 Harrington Road, Fallon, Nev. 89406
ADDRESS AT WELL LOCATION 3878 Boyer Lane, Fallon, Nev. 89406

2. LOCATION SE ¼ SE ¼ Sec. 7 T. 18 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 12 | Subdivision Name Boyer

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Coarse Brown Sand		3	16	13
Sandy Brown Clay		16	23	7
Brown Coarse Sand		23	26	3
Green Sand		26	33	7
Green & Brown Coarse Sand		33	37	4
Green Sand		37	39	2
Brown Clay		39	43	4
Green Sand		43	52	9
Green & Brown Coarse Sand		52	58	6
Green Clay		58	63	5
Brown Clay		63	70	7
Brown Coarse Sand	X	70	76	6

Date started December 4, 19 91
Date completed December 4, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 76 Feet Depth Cased 76 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	76 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	76

Perforations:
Type perforation Millcut
Size perforation 1/8"
From 71 feet to 74 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 76 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nev. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Jan. 2, 1992

'92 JAN -6 P2:44 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627