WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37914
Permit No.
Basin 102

NOTICE OF INTENT NO. 16978

1. OWNER Enid H. Clements
MAILING ADDRESS 3300 Highway 50
Carson City, NV 89706
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 35 T. 18 N/S R. 24 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) | 15-211-22 (Parcel No.) | Tenaya-Lumas LOT #2 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt, and chips of Broken shale		0	3	3
Brown & Black Colored shale		3	22	19
Red Clay & shale Mixed		22	30	8
Brown Colored shale		30	35	5
Dark Brown Hard Dense shale		35	58	23
Dark Brown Clay		58	60	2
Gray-Black shale		60	170	110
Hard Black shale		170	220	50
Hard Black shale some quartz mixed		220	240	20
Hard Black Broken shale with large amt. of Quartz (FAULT AT 250')	✓	240	260	20

Date started 3/19, 19 91
Date completed 3/20, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+	240	3 Hrs

8. WELL CONSTRUCTION
Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	60' Feet
8 3/4 Inches	60 Feet	260 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+1	260

Perforations:
Type perforation Torch Cut
Size perforation 3/16 X 6"
From 240 feet to 260 feet
From feet to feet
From 54 Rows feet to 100 perforations
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60' feet to 260' feet

9. WATER LEVEL
Static water level 184 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc. (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L. Leach (By driller performing actual drilling on site or contractor)
Date 3/30/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627