

OFFICE USE ONLY
Log No. 37947
Permit No. 104. BAGUEN.
Basis 104. BAGUEN.

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13674

1. OWNER Carson City Public Works ADDRESS AT WELL LOCATION 125' NE
MAILING ADDRESS 3300 Butte Way Bennett Ave
Carson City, Nevada 89701 Carson City, Nevada
2. LOCATION SW 1/4 NW 1/4 Sec between r. 15 X/S R 20 E Carson City County
PERMIT NO. 56531 Waiver 349 32/33 NA
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hardpan		0	8	8
Clay/Sand/DG		8	25	17
Stringers Clay/ DG		25	130	105
Granite/Bedrock		130	248	118
Abandon #45				
Set 2" Tremmie Pipe		0	220	
Pumping Grout				
Pull 20'		220	200	
Pumping Grout				
Pull 20'		200	180	
Pumping Grout				
Pull 20'		180	160	
Pumping Grout				
Pull 20'		160	120	
Pumping Grout				
Pull 20'		120	100	
Pumping Grout				
Pull 20'		100	80	
Pumping Grout				
Pull 20'		80	60	
Pumping Grout				
Pull 20'		60	40	
Pumping Grout				
Pull 20' and top off well				

Abandoning was done in accordance to the rules and regulations of the State of Nevada. Engineer observed this job.

Date started 9/23, 1991
Date completed 9/24, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	NA		

8. WELL CONSTRUCTION
Depth Drilled 248 Feet Depth Cased..... Feet
HOLE DIAMETER (BIT SIZE)
From To
8 1/4" Inches 0 Feet 248 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		NA		

Perforations:
Type perforation.....
Size perforation NA
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet

Surface Seal: Yes No Seal Type:
Depth of Seal 248 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No 7 BAG MIX
From..... feet to..... feet

9. WATER LEVEL
Static water level DRY feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature..... °F Quality.....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling And Pump Co., Contractor
Address P.O. BOX 590 Contractor
Winnemucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1533
Signed C. E. Epler
By driller performing actual drilling on site or contractor
Date 10-9-91