

OFFICE USE ONLY
Log No. 37948
Permit No. 104-EAGLE V.
Basin 104-EAGLE V.
13674

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13674

1. OWNER Carson City Public Works ADDRESS AT WELL LOCATION 900' E Bennett Ave Carson City, Nevada
MAILING ADDRESS 3300 Buttle Way Carson City, Nevada 89701
2. LOCATION S W 1/4 Sec 33 T. 15 N/S R. 20 E Carson City County
PERMIT NO. 56531 W 349 Issued by Water Resources Parcel No. NA Subdivision Name NA

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy / DG Clay		0	7	7
Sandy/DG/SM Gravel		7	10	3
Granite / Bedrock		10	92	82
Fractured Bedrock/ Granite		92	115	23
Hard Granite/Bedrock		115	122	7
Abandon #45c	<u>7 BAG MIX</u>		<u>2 yds</u>	
Set 2" Tremmie Pipe		0	115	
Pumping Grout				
Pull 20'		115	95	
Pumping Grout				
Pull 20'		95	75	
Pumping Grout				
Pull 20'		75	55	
Pumping Grout				
Pull 20'		55	35	
Pumping Grout				
Pull 20'		35	15	
Pumping Grout				
Pull and grout to surface				

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased X Feet
HOLE DIAMETER (BIT SIZE)
From 8 1/2 Inches 0 Feet 125 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
NA
Perforations:
Type perforation NA
Size perforation
Surface Seal: Yes No Seal Type:
Depth of Seal 125 Neat Cement Cement Grout Concrete Grout
Placement Method: Pumped Poured 7 BAG MIX
Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 9/30, 19 91
Date completed 9/30, 19 91

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		<u>NA</u>	

9. WATER LEVEL
Static water level DRY feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co Contractor
Address P.O. BOX 590 Winnemucca, Nevada 89446-0590 Contractor
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed C. E. Eagle
By driller performing actual drilling on site or contractor
Date 10-11-91