

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 16387

PRINT OR TYPE ONLY

1. OWNER Bentley Nevada Corporation ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1617 Water Road Bentley Nevada Corporation  
Minden, NV 89423 Airport Facility, Minden, Nevada  
 2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 14 N/S R. 20 E Douglas County  
 PERMIT NO. 5677E Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dirt-sand-silt clay		0	3	3
large-small sand & gravel		3	52	49
Silt & clay		52	57	5
Sands-gravels		57	67	10
Clay		67	73	6
Silt & clay		73	82	9
Clay		82	84	2
Large-small gravels		84	90	6
Brown silt		90	94	4
Large-small sands & gravels		94	107	13
Large-small sands & gravels in Thin Layers		107	113	6

8. WELL CONSTRUCTION  
 Diameter 12-1/4 inches Total depth 113 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6-5/8  
 Weight per foot 17.02 Thickness .250  

Diameter	From	To
<u>6-5/8</u> inches	<u>+5</u> feet	<u>113</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Neat cement  
 Depth of seal 88 feet  
 Gravel packed: Yes  No   
 Gravel packed from 90 feet to 113 feet  
 Bentonite Pellets 88' to 90'  
 Perforations:  
 Type perforation Johnson screen  
 Size perforation \_\_\_\_\_  
 From 93 feet to 113 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started November 8, 19 91  
 Date completed November 15, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level +2 feet below land surface  
 Flow 10 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sargent Irrigation Company Contractor  
 Address 9955 N. Virginia St., Reno, NV 89506 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada contractor's driller's number issued by the Division of Water Resources 1391  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date January 16, 1992