WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37996
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 18520

1. OWNER Bob March
MAILING ADDRESS 3003 W. Holcomb Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION
3003 W. Holcomb Lane
Reno, NV 89511

2. LOCATION NE ¼ NW ¼ Sec 12 T 18N N/S R 19 E Washoe County

PERMIT NO. (Issued by Water Resources) | 040-650-03 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We perforated the well casing from 90' to about 40' with "Mills Knife" every 2 feet with 4 perforations at each level. We increased the yield of the well from 16 gpm with pumping level of 79', to 25+ gpm with pumping level 28'. After 6 hours of pumping 18-20 gpm the pumping level was about 32' and static level was 22'. No cement seal was encountered. The well is said to be about 40 years old.				

'91 OCT 16 A11:02 STATE ENGINEER'S OFFICE

Date started Oct 11, 1991
Date completed Oct 11, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	6	15 min
18-20	10	6 hours

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Mills Knife
Size perforation
From 90 feet to 40 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No ?
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No ?
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 10-11-'91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627