

OFFICE USE ONLY
 Log No. 37999
 Permit No. _____
 Basin. 88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14980

1. OWNER John Beannweg ADDRESS AT WELL LOCATION 15630 PAVEN
 MAILING ADDRESS Box 18116 Reno NV. 89511 LANE Reno NV.
 2. LOCATION NW 1/4 SW 1/4 Sec. 36 T. 18 N. R. 19 E. WASHCO County
 PERMIT NO. 49-132-02 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0'</u>	<u>5'</u>	<u>5'</u>
<u>Soft Sand</u>		<u>5'</u>	<u>65'</u>	<u>60'</u>
<u>Hard broken Boulders</u>		<u>65'</u>	<u>75'</u>	<u>10'</u>
<u>Firm Sandstone</u>		<u>75'</u>	<u>110'</u>	<u>35'</u>
<u>Gravels w/some water</u>	<u>X</u>	<u>110'</u>	<u>130'</u>	<u>20'</u>
<u>Gravels/w WATER</u>	<u>XXX</u>	<u>130'</u>	<u>140'</u>	<u>10'</u>
<u>T.D. 140</u>				
<u>Gpm 20+</u>				
<u>Static 70'</u>				

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

From <u>11 3/4</u> Inches	To <u>0</u> Feet	<u>55'</u> Feet
<u>10 3/4</u> Inches	<u>55</u> Feet	<u>140'</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>140'</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3/2 x 3/32
 From 120' feet to 140' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55' feet to 140' feet

9. WATER LEVEL
 Static water level 70' feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature Cold °F Quality Good

Date started 12-18, 191
 Date completed 12-19, 191

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>45'</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name H & H Pump Co. Contractor
 Address 5551 N. Y. St. East #3 Carson City NV. 89701 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joe Rutt By driller performing actual drilling on site or contractor
 Date 12/19/91