

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20124

1. OWNER LOUI DEMONTE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 144 Storey Way 125 Sage Hill
Reno, NV 89511 Reno, NV 89511
 2. LOCATION SE 1/4 NW 1/4 Sec 21 T 18N N/S R 20 E Washoe County
 PERMIT NO. 16-400-67 Near VC Foothills area
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black top soil		0	4	4
Brown clay		4	7	3
Rusty brown sandy clay		7	12	5
Granite boulder		12	14	2
Rusty brown sandy clay and gravels		14	23	9
Brown volcanic gravels & sand with some clays		23	27	4
Brown clay with gravels		27	40	13
Soft sand(volcanic & granite sands)		40	43	3
Brown clay with gravels & sands		43	52	9
Brown sandy clay		52	59	7
Soft zone	X	59	63	4
Brown sandy clay		63	71	8
Soft zone(granite sands)	X	71	77	6
Blue sandy clay		77	80	3
NOTE: WATER TEMPERATURES				
		154°F at 80 feet		
		114°F at 40 feet		
		92°F at 10 feet		

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 80 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10</u>	<u>0</u>	<u>50</u>	<u>Feet</u>
<u>9 7/8</u>	<u>50</u>	<u>80</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>80</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 55 feet to 75 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 (waiver) Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 80 feet

9. WATER LEVEL
 Static water level 7.5 feet below land surface
 Artesian flow 60± G.P.M. P.S.I.
 Water temperature (see 6) F Quality not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.
 Address P.O. Box 12370, Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 22549
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date September 30, 1991

Date started 9-24-91, 19____
 Date completed 9-26-91, 19____

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			