WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38013
Permit No.
Basin 6-88

NOTICE OF INTENT NO. 18644

1. OWNER Rich Sturdivant
MAILING ADDRESS 201 W. Laramie
Reno, NV 89511

ADDRESS AT WELL LOCATION
201 W. Laramie
~~XXX~~ Reno, NV 89511

2. LOCATION NW ¼ SE ¼ Sec. 7 T. 17N N/S R. 20 E. Washoe County

PERMIT NO. (Issued by Water Resources) 045-321-06 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon 6 5/8" well which was 117' deep but due to corroded casing or obstruction, we perforated the casing at approximatly 5' intervals from 80' to about 56'. We then filled the well using neat cement at 6 to 1 ratio using approximately 4 yards cement and pumped by tremie pipe from bottom to top. Water level was approximately 12' from surface before abandonment. The casing was so corroded or thin that perforation at the intervals indicated was done with very little pressure. A mechanical "Mills Knife" was used for the perforations.				

92 NOV 12 P1:13
STATE ENGINEER

Date started 11-4, 1991
Date completed 11-4, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719

Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor

Date 11-6-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627