


OFFICE USE ONLY
 Log No. 38017
 Permit No. _____
 Basin 6-29



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17988

1. OWNER LUSILLE TINBURG ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3315 Lyon Lane 3145 Whitepine
Carson City, NV 89704 Carson City, NV 89704

2. LOCATION NW 1/4 NE 1/4 Sec. 6 T. 16N N/S R. 20 E Washoe County
 PERMIT NO. 050-422-10 New Washoe City
Issued by Water Resources Parcel No. subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Gray clay		63	71	8
Soft zone	X	71	76	5
Gray-blue clay, sandy		76	108	32
Soft zone (coarse sands)	X	108	115	7
Gray-blue clay		115	121	6
Coarse sands	X	121	123	2
Soft sand blue clay		123	127	4

'91 NOV -7 AM:35
 STATE ENGINEERS (FEIN)

8. WELL CONSTRUCTION
 Depth Drilled 64 Feet Depth Cased 127 Feet

HOLE DIAMETER (BIT SIZE)
 From To
5"OD Inches 0 Feet 127 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	127

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around

From 64 feet to 84 feet
 From 104 feet to 124 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ n/A _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60 feet to 127 feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow 18 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

Date started 10-30-91, 19____
 Date completed 10-30-91, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date November 1, 1991