WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38023
Permit No.
Basin 6-89

NOTICE OF INTENT NO. 17452

1. OWNER Bob Papenforth 4030 Woodcock
MAILING ADDRESS 4030 Woodcock, Washoe Valley, Nev.
ADDRESS AT WELL LOCATION 4030 Woodcock Washoe Valley, Nev.

2. LOCATION NE ¼ SE ¼ Sec. 32 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources | 50-416-12 Parcel No. | New Washoe City Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Granit	X	115	125	10
Granit, Few Fractures	X	125	280	155

Apparent depth of existing well (6") is 115 Ft.

Per conversation w/ Bruce MacKay Pump 3 Drill on 7-20-06, TD of well is actually 243 ft with liner @ 73 ft. Shift perfs up by 37 ft.
RL 8-9-06

RECEIVED STATE ENGINEERS OFFICE '91 OCT 16 AM 1:02

Date started 9/13, 1991
Date completed 9/19, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10+		2

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased liner 170 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	115 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16		0.188	110	180
5		0/188	180	280

Perforations:
Type perforation Factory Slotted
Size perforation 3/32 X 3"
From 180 feet to 200 feet
From 220 feet to 240 feet
From 260 feet to 280 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pre-Cambrian Drilling Co. Inc. Contractor
Address 794 Foothill Rd. Gardnerville Contractor
Nev. 89410
Nevada contractor's license number issued by the State Contractor's Board 0030267
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1652
Signed By driller performing actual drilling on site or contractor
Date 10/10/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627