

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18264

1. OWNER LDS church ADDRESS AT WELL LOCATION 440 McClellan
 MAILING ADDRESS 855 Industrial Way
Sparks, Nv 89431

2. LOCATION SW 1/4 NE 1/4 Sec. 32 T. 17 N/S R. 20 E Washoe County
New Washoe City
 PERMIT NO. 38904 050-371-17 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard granite gray & white with fractures		375	460	85
Noticeable water at start of 440 rod				
There is a 20 foot blank on the bottom of perforations				
T.D. 460 feet				
<i>Deepening of log # 20925</i>				
<i>91 NOV 20 10 54 STATE ENGINEER</i>				

8. WELL CONSTRUCTION
 Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)
 From 7 7/8 Inches 215 Feet 460 Feet
 To Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	200	460

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3 double
 From 400 feet to 440 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal Refer to original log Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level 113 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 11/7/91

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		<u>2</u>
<u>30</u>	<u>150 ft</u>	<u>1</u>

Date started 11/1/91, 19.....
 Date completed 11/5/91, 19.....