WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38044
Permit No.
Basin 8-104

NOTICE OF INTENT NO. 17557

1. OWNER Wes & Janealle Franklin
MAILING ADDRESS 3530 Voltaire Canyon Road
Carson City, Nev. 89703

ADDRESS AT WELL LOCATION 3530 Voltaire Canyon Road
Carson City, Nev. 89703

2. LOCATION SE ¼ NE ¼ Sec. 26 T. 15 N/S R. 19 E. Carson City County
PERMIT NO. N/A (Issued by Water Resources) 007-051-28 (Parcel No.) Voltaire Canyon (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Clay		0	8	8
Green Clay		8	20	12
Tan Sand		20	50	30
Tan Clay		50	67	17
Gravel & White Sand	X	67	72	5
Red Clay & Sand		72	90	18
Granite Shelf		90	91	1
Red Clay		91	96	5
Gravel	X	96	106	10
Granite		106	108	2
Red Clay		108	112	4
Gray Clay		112	128	16
Gravel	X	128	130	2
Granite		130	240	110

Date started November 5, 19 91
Date completed November 14, 19 91

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8-3/4 Inches		0 Feet	130 Feet
5-3/4 Inches		130 Feet	240 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4-1/2	8.66	.188	0	240

Perforations:
Type perforation Torch Cut
Size perforation 1/16"--1/8"
From 70 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nev. 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696

Signed [signature] (By driller performing actual drilling on site or contractor)

Date 12-5-91

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627