


OFFICE USE ONLY
 Log No. 38054
 Permit No. _____
 Basin 49



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19210

1. OWNER JAY B NIXON ADDRESS AT WELL LOCATION ONE Lot West of
 MAILING ADDRESS MUR # 295-1 Apache STREET on Center STREET
EIKO N.V. 89801 North side of STREET

2. LOCATION NW 1/4 SW 1/4 Sec 3 T 35 N/S R. 56 E. EIKO County _____
 PERMIT NO. Lot 7 Blk 20 MUR # 3
 Issued by Water Resources 35-070-07-2 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	15	15
CLAY		15	70	55
Void		70	70.5	15
CLAY		70.5	145	69.5
Gravel	Water	145	160	15

92 JAN 27 P 3:00
 RECEIVED
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>+2</u>	<u>160</u>

Perforations:
 Type perforation slots
 Size perforation 3/4" x 3"
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60 feet to 160 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

Date started 12-31, 1991
 Date completed 1-7, 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>4 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fentig Drilling Co Contractor
 Address P.O. Box 525 Contractor
EIKO N.V. 89801

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shoultz Fentig
 By driller performing actual drilling on site or contractor
 Date 1-15-92