

OFFICE USE ONLY
 Log No. 3806
 Permit No. _____
 Basin. 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18272

1. OWNER Michael & Kathleen Boyce ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3921 Greenbriar off Mt. Rose Hwy
Reno, Nv 89509

2. LOCATION SE 1/4 SE 1/4 Sec. 25 T. 19 N/S R. 18 E. Washoe County
 PERMIT NO. 049-210-003 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Volcanic rock & clay		0	29	29
Clay & volcanic rock		29	71	42
Multi colored volcanic rock & clays [mostly black rock]		71	194	123
White & gray clay		194	221	27
Gray white & black D.G. medium hard	X	221	251	3
Hard rock, gray white black		251	259	8
T.D. 259 feet				

8. WELL CONSTRUCTION
 Depth Drilled 259 Feet Depth Cased 259 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 58 Feet
 10 5/8 Inches
 8 1/2 Inches 58 Feet 259 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	259

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 229 feet to 249 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 52 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 52 feet to 259 feet

9. WATER LEVEL
 Static water level 129 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132- 1804
 Division of Water Resources, the onsite driller.

Signed Roger [Signature]
 By driller performing actual drilling on site or contractor
 Date 1/20/92

Date started 1/16/92, 19_____
 Date completed 1/16/92, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>1 1/2</u>

92 MAR 24 A 9 54
 STATE ENGINEERS OFFICE