

OFFICE USE ONLY
Log No. 38064
Permit No. _____
Basin 87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16681

1. OWNER Rodney Fair ADDRESS AT WELL LOCATION 2570 TACCHINO, RENO, NV
MAILING ADDRESS 1646 Nevada Way
Bozeman City, NV 89005

2. LOCATION SW 1/4 SW 1/4 Sec 6 T 19 R 20 E WASHOE County
PERMIT NO. W10-493 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt Concrete	No	0	1.5'	1.5'
Brown clayey sand	No	1.5	3	2.5'
Brown gravelly sand	No	3	8	5'
Sandy gravel	No	8	26	18'
Brown sand	No	26	31	5'
Gray sandy gravel with cobbles	No	31	48	17'
Sandy gravel with abundant clay	YES	48	52	4'

92 MAR 24 AM 113
STATE ENGINEERS

8. WELL CONSTRUCTION
Depth Drilled 52 Feet Depth Cased 52 Feet

HOLE DIAMETER (BIT SIZE)
From 5 Inches To 52 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>SCH-40 PVC</u>		<u>0</u>	<u>52</u>

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 42 feet to 52 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 0-37' Benlon Neat Cement
Placement Method: Pumped PWG Cement Grout
 Poured 37-40' Concrete Grout

Gravel Packed: Yes No
From 40 feet to 52 feet

9. WATER LEVEL
Static water level 47.9 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 62.0 °F Quality N/A

Date started JAN 9, 1992
Date completed JAN 10, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Andrew Contractor
Address 1635 Belford RD, Reno, NV, 89509 Contractor

Nevada contractor's license number issued by the State Contractor's Board _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028

Signed Paul Andrew
By driller performing actual drilling on site or contractor
Date 3/2/92