WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38077
Permit No.
Basin 89

NOTICE OF INTENT NO. 18526

1. OWNER Kendall Haag
MAILING ADDRESS P.O. Box 1296
~~Carson~~ Reno, NV 89510

ADDRESS AT WELL LOCATION
3227 Old Hwy 395 North.
Carson City, NV 89701

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 17N N/S R. 19 E. Washoe County

PERMIT NO. (Issued by Water Resources) | Parcel No. 046-031-35 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Rock, boulders, d.g. | | 0 | 70 | 70 |
| Cobbles, d.g. | x | 70 | 80 | 10 |
| Clay | | 80 | 105 | 25 |
| Sm. rocks and d.g. | x | 105 | 145 | 40 |
| D.G. | x | 145 | 200 | 55 |

'92 JAN 14 A10:41
STATE ENGINEER'S OFFICE

Date started 12-20-'91, 19
Date completed 1-09-'92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 50+ | | 2 hours |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 197 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 | 0 | 100 |
| 6 | 100 | 200 |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | 0 | 129 |
| 5" | 10.79 | .188 | 117 | 197 |
| | | | | |

Perforations:
Type perforation Saw
Size perforation 3/32 x 3"
From 109 feet to 129 feet
From 157 feet to 197 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100' 2 yards.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1-13-'92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627