WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38084
Permit No.
Basin 92A

NOTICE OF INTENT NO. [illegible]

1. OWNER BWC West Inc.
MAILING ADDRESS 1234 Market Street Philadelphia PA 19107
ADDRESS AT WELL LOCATION Master Halco 14331 Lear Blvd Reno/Stead NV

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 21 (N)S R. 19 E. Washoe County
PERMIT NO. MO 181 B (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG EW #11

Material	Water Strata	From	To	Thickness
Clayey Sand	No	0	5	5
Sandy Clay	No	5	7.5	2.5
Sandy Silt	No	7.5	10	2.5
Gravelly Clay	No	10.0	12.5	2.5
Brown Silt	Yes	12.5	15.0	2.5
Sandy Clay	Yes	15	16.5	1.5

'92 MAR 24 AM 10:12
STATE ENGINEER'S OFFICE

Date started 1-23, 1992
Date completed 1-23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 16.5 Feet Depth Cased 16.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	16.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch. 40	PVC	0	16.5

Perforations:
Type perforation Factory Slot
Size perforation .020 Inch
From 6.5 feet to 11.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5.5 feet
Placement Method: ☒ Pumped Neat Cement ☐ Poured w/5% Bentonite
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5.5 feet to 12.0 feet

9. WATER LEVEL
Static water level 7.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address 1635 Belford RD Contractor
RONO NEV. 89509
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/2/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627