WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38107
Permit No.
Basin 108

NOTICE OF INTENT NO. 19356

1. OWNER E.L. Gentry
MAILING ADDRESS P.O. Box 374
Yerington Nev 89447

ADDRESS AT WELL LOCATION #7 Wyatt Dr
Yerington Nev 89447

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 12 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 012-231-47 (Parcel No.) Parcel 2D (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand		0	8	8
Clay + Coarse Sand		8	10	2
Coarse Sand + Rock		10	18	8
Clay + Coarse Sand		18	36	18
Coarse Sand		36	40	4
Coarse Sand, Rock, Clay		40	52	12
Coarse Sand, Gravel, Clay		52	70	8
Coarse Sand, Rock		70	72	2
Clay + Coarse Sand		72	74	2
Coarse Sand, Rock		74	82	8
Clay + Coarse Sand		82	98	16
Coarse Sand (Sed)		98	110	12
Clay + Coarse Sand + Rock		110	114	4
Coarse Sand (Sed)		114	135	21
Coarse Sand + Clay		135	147	12
Clay + Sand Stratas		147	152	5
Clay		152	168	16
Coarse Sand, Gravel + Rock	X	168	180	12
Coarse Sand, Gravel Rock with Clay	X	180	183	3
Coarse Sand, Gravel Rock	X	183	184'10"	1'10"

Date started 3- 19, 1992
Date completed 3- 25, 1992

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw-Down (Feet Below Static)	Time (Hours)
Bailed	22	4	1/2

8. WELL CONSTRUCTION
Depth Drilled 184'10" Feet Depth Cased 185'10" Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	+1 Feet	184'10" Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	184'10"

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3" 6 Rows
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 184'10" feet

9. WATER LEVEL
Static water level 45' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold to 81 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling (Contractor)
Address 162 N By Bee Lane (Contractor)
Yerington Nev 89447

Nevada contractor's license number issued by the State Contractor's Board 15646

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed Lay Ogden
By driller performing actual drilling on site or contractor
Date 3-28-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627